Machine Translated by Google
NOMOS - Multidisciplinary Scientific Journal
Knowledge. ISSN: 2675-9128. São Paulo-SP.

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

Energy resilience in critical facilities: integration of solar generation, storage and generator sets.

Energy resilience in critical facilities: integration of solar generation, storage and generator sets
Energy resilience in critical installations: integration of generation, storage and solar generators

Adriano Cesar Notari

Electrical Engineer, Civil Engineer, specialist in Electrical Installations and Engineering.
Workplace Safety

Summary

This article examines the fundamentals of design, sizing, protection, and operation of hybrid systems intended for the continuity of critical facilities. The narrative review integrates scientific literature, reports from international organizations, and technical guides relevant to the topic. The complementarity between photovoltaic generation, electrochemical storage, generating units, and the public grid is discussed, paying attention to time profiles, uncertainty, component failures, power quality, grounding, maintenance, and governance. The analysis argues that resilience does not result from the sum of equipment, but from the verifiable coordination between sources, controls, protections, and procedures. The work does not present experimental testing or a universal protocol; it offers a critical synthesis to support engineering decisions and defines the conditions necessary for the responsible interpretation of autonomy and availability metrics.

Keywords: energy resilience; microgrids; photovoltaic generation; energy storage; generator sets; critical installations

Abstract

This article examines design, sizing, protection and operational foundations of hybrid systems intended to maintain critical facilities. The narrative review integrates scientific literature, reports from international organizations and technical guides relevant to the subject. It discusses the complementary roles of photovoltaic generation, electrochemical storage, generator sets and the public grid, with attention to hourly profiles, uncertainty, component failures, power quality, grounding, maintenance and governance. The analysis argues that resilience does not result from merely adding equipment, but from verifiable coordination among sources, controls, protections and procedures. The paper does not present an experimental test or a universal protocol; it offers a critical synthesis to support engineering decisions and defines conditions required for responsible interpretation of autonomy and availability metrics.

Keywords: energy resilience; microgrids; photovoltaic generation; energy storage; generator sets; critical facilities

Introduction

The continuity of electricity supply has become a structural requirement for health services.

Telecommunications, water treatment, data processing, security, and manufacturing. A

The reliance on electronic controls and communication networks has increased the likelihood of interruptions.

At the same time, extreme weather events, fires, technical failures, and digital threats...

They challenge systems designed only for average conditions. The International Energy Agency

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

It emphasizes that electrical safety requires adequacy, flexibility, stability, and institutional capacity.
especially in systems with an increasing share of variable resources (IEA, 2021).
Generator sets have historically been the most common backup solution, but their reliability...
It depends on starting, fuel, maintenance, ventilation, and transient conditions. The diffusion of
Photovoltaic generation and batteries have created architectures. These resources can reduce consumption and emissions.
and, when configured for stand-alone operation, sustain loads during failures. However, integration
It introduces control, protection, grounding, and management requirements that do not appear when
Equipment is evaluated separately.
The literature uses different definitions of resilience. In this article, the term indicates the capacity to
To anticipate, absorb, adapt to, and recover from disturbances, while maintaining priority functions. This
The definition avoids reducing resilience to historical reliability or nominal autonomy. Performance
It depends on the event, the load, and the state of the system at the time of the interruption. An architecture
Suitable for short-term outages, it may be insufficient in the face of prolonged regional unavailability.
The goal is to synthesize criteria for designing and managing hybrid systems in critical facilities.
Distinguishing potential benefits from necessary conditions. The guiding question is: which elements
Technical and organizational factors enable solar generation, storage, and generator sets.
How can they contribute in a coordinated way to resilience? The text addresses metrics, architecture,
sizing, solar expansion, protection, maintenance and governance, without converting the review into
universal prescription.

Methodology

A narrative and critical literature review was conducted, suitable for integrating concepts from...
power engineering, microgrids, storage, reliability, and asset management. They were
Priority is given to peer-reviewed articles and publications from the International Energy Agency.
International Renewable Energy Commission and the National Renewable Energy Laboratory, in addition to standards
recognized.
The conceptual search considered combinations of terms related to electrical resilience and microgrids.
Hybrid systems, photovoltaic generation, batteries, diesel generators, critical installations, protection and operation.
The selection prioritized documents with a described methodology, identifiable scope, and relevance to...
Design decisions. Commercial sources and texts without technical authorship have been excluded. Data
Quantitative figures were used only when accompanied by unit, period, and institution.
responsible.

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

The synthesis was organized by engineering function. Each piece of evidence was interpreted according to its...
context, distinguishing case studies, modeling, review, and global statistics. Results of a
Installation rates were not generalized as universal rates. The graph uses values published by
IRENA for global solar capacity is descriptive in nature. It does not demonstrate a causal relationship.
between photovoltaic expansion and the resilience of an installation.
As limitations, the review did not perform meta-analysis, experimentation, or validation of a method.
Sizing. National standards and utility requirements vary by jurisdiction and should...
to be verified in each project. The conclusions represent convergences with the literature and criteria.
analytical, not replacing electrical studies, risk assessment, technical responsibility or
specific commissioning.

1. Energy resilience as a measurable design attribute

Energy resilience should not be confused with the average availability observed over periods of
Regular operation. It describes the ability of a facility to anticipate disturbances, withstand the
partial or total loss of external supply, maintain priority cargo and recover functions within
defined time limits. Microgrid literature recommends that performance be evaluated.
by interruption scenarios, probable event duration, hourly load profile and consequence of
unavailability. This approach shifts the design away from a logic focused solely on power.
nominal for an analysis oriented towards functional continuity and risk (ANDERSON et al., 2019;
NELSON et al., 2020).1
In critical installations, load classification is the first relevant analytical decision.
Protection systems, communication, emergency lighting, essential cooling, pumping.
Data processing and management may present distinct requirements for quality and autonomy. (Add more information here.)
Installed power without considering simultaneity, starting current, power factor, and sequence.
Restoration efforts tend to produce solutions that are oversized or incapable of addressing the problem.
Real-world event. Resilience engineering requires load curves, functional inventory, and criteria.
explicit priorities, since the energy available during a contingency must be allocated according to
the criticality of the service.
The measurement can combine indicators such as unsupplied energy, maximum tolerable time of
interruption, autonomy for critical load, and probability of survival during an outage.
with a defined duration. No single indicator replaces systemic analysis. An arrangement may

1In this article, a critical installation is defined as one whose power loss has significant consequences for safety, health, the environment, information, or service continuity.

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

to exhibit high theoretical autonomy and, at the same time, fail due to device unavailability.
transfer, battery degradation, lack of fuel, or protection coordination error.
Therefore, energy metrics need to be associated with failure modes, periodic tests, and conditions.
environmental and maintainability.
The International Energy Agency notes that electrical safety has gained importance as...
economies and services are becoming more dependent on electricity. Digitization, air conditioning,
Electric mobility and automation amplify the consequences of disruptions, even when...
The frequency of failures remains low. This change makes addressing the supply of insufficient.
Emergence as a peripheral element. The power supply architecture, the means of transfer, the
Selectivity and operational observability become central to asset performance.
(IEA, 2020).
The technical decision must also recognize that resilience has a cost and value that depend on the context.
The interruption of an administrative workload can be postponed, while the loss of ventilation,
Telecommunications or process control can produce immediate effects. The comparison between
Alternatives should consider investment, operation, fuel, component replacement,
Emissions, maintenance, and avoided downtime costs. Therefore, the most resilient solution is not...
necessarily the one with the greatest installed capacity, but the one that supports priority functions with
Demonstrable reliability and consistent life-cycle cost.

2. Hybrid architecture and coordination between sources

A hybrid architecture combines resources with temporal responses and complementary characteristics.
Photovoltaic generation reduces grid consumption and can contribute during daytime events, but it depends
of irradiance and the ability to operate in islanded mode. Batteries respond quickly,
They stabilize transitions and handle short-duration variations. Generator sets provide power.
Dispatched as long as there is fuel and adequate mechanical conditions. The public network, when
available, it remains as a primary or supplementary source. The value of the set stems from
coordination between these elements, and not simply the physical presence of each technology.2
The central point of coordination is the instantaneous balance between generation and load. In plugged-in mode,
Inverters can operate following the frequency and voltage of the grid. In islanded mode, some feature
It needs to establish electrical references and maintain stability in the face of load changes.
Grid-forming inverters, batteries, and synchronous machines have distinct responses. The transition

2The nominal battery capacity does not fully correspond to the usable energy due to discharge limits, efficiency, temperature, aging, and operational reserve.

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

It should be studied in terms of transfer time, voltage dips, frequency, and current.
Short-circuit and motor starting capability. The control architecture needs to be compatible.
with the protections and limitations of each piece of equipment.
The addition of storage alters the dispatch logic. The battery can remain reserved for
contingencies, implement peak reduction, absorb surplus solar energy, or provide more than one service.
according to a hierarchy. Aggressive economic arbitrage strategies can diminish the state.
of available load when an interruption occurs. On the other hand, maintaining full reserve reduces the
economic exploitation of the asset. The literature recommends optimization that incorporates uncertainty of
Failures and preserve an energy margin associated with criticality, weather forecast, and time.
expected generator mobilization (IEA, 2024).
The generator set remains relevant in prolonged events, but its reliability depends on...
Factors that power calculations don't reveal: Unsuccessful starts, degraded fuel, malfunctions.
Delayed maintenance and prolonged operation at low load can reduce the starting battery.
performance. Comparative studies show that microgrids with photovoltaic generation,
Networked storage and generators can outperform diesel-only setups in resilience.
and life cycle cost, provided that the project accounts for component failures and logistics of
fuel (MARQUSEE; BECKER; ERICSON, 2021).
The coordination should foresee clear operational states, entry and exit conditions, priorities and
Response to internal failures. Modes such as normal operation, preventive charging, contingency,
Islanding, restoration, and return to the grid need to be documented. Electrical interlocks and
Logic controllers must prevent improper paralleling and unsafe power supply. Supervision must record this.
sufficient magnitudes, alarms, and commands for later analysis. This discipline reduces ambiguities.
and transforms a set of equipment into an effectively manageable energy system.

3. Technical dimensioning under uncertainty

Conventional sizing based on a single typical day does not adequately represent the
Resilience. Irradiance, temperature, load, and interruption duration vary, while degradation
This modifies the usable energy of the battery over the years. A robust analysis uses series of data.
temporal, seasonal scenarios, and plausible extreme events. The goal is to verify how many hours or
On what days can critical loads be serviced, and what combinations of failures lead to loss of service?
Deterministic models are useful for screening, but the uncertainty must be explicitly stated when...
The consequence of the failure is high.
Photovoltaic power should be estimated to account for losses due to temperature, dirt, shading,
Conversion, unavailability, and orientation. The projected annual energy does not guarantee contribution during

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

a specific contingency. In a nighttime event, the solar source does not provide immediate power; in
On cloudy days, production may remain below average. Therefore, the share of photovoltaics in
Resilience should be calculated using hourly profiles, not monthly averages. The use of data
Representative meteorological data allows for the quantification of performance ranges and avoids making empty promises.
autonomy without foundation.

In storage, power and energy are different variables. Power determines capacity.
to handle peak demand and form the network, while the energy supply determines the duration of the service. Depth
Discharge capacity, efficiency, temperature, discharge rate, and aging all reduce capacity.
Available. The operational reserve also limits usage. The specification should include end-of-use criteria.
lifespan, expansion, thermal safety, protection, ventilation, and replacement strategy. Sizing
Using only the initial nominal capacity transfers a risk to the operation that should have been addressed.
in the project.

The generator set is selected considering service conditions, transient characteristics, altitude,
Temperature, fuel, noise, emissions, and maintenance. Loads with motors, elevators,
Transformers or power electronics may impose conditions different from those indicated by
Total active power. The load input sequence reduces steps and can allow equipment
Smaller, but requires reliable automation. Operating in parallel with other resources demands further study.
synchronization, load sharing, protection, and grounding. These requirements demonstrate
Because catalogs are no substitute for application engineering.

Optimization tools can compare thousands of combinations, but the result depends
of the premises. Fuel costs, discount rate, value of unsupplied energy, useful life and
Operational constraints must be transparent. A mathematically optimal value can be technically...
Fragile if maintenance, parts availability, or team competence are ignored. The decision must
It undergoes sensitivity analysis and engineering review. Modeling serves to make choices.
auditable, not to eliminate professional judgment.

4. Solar expansion and the role of storage

The expansion of photovoltaics has altered the scale of the integration problem. According to the International Agency
In the renewable energy sector, global solar photovoltaic capacity has increased from approximately 710 GW.
by the end of 2020, this growth will increase to 1,865 GW by the end of 2024. This growth expands the availability of generation capacity.
low cost, but it also increases the need for flexibility, adequate networks, control and
storage. The global data does not determine the solution for a specific installation, however

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

This demonstrates that technologies that were previously peripheral have become central to infrastructure decisions.
energy (IRENA, 2025).3

Batteries can reduce losses and congestion, shift energy over time, and support integration.
from variable sources. The International Energy Agency estimates that the global capacity of
Storage will need to grow significantly to safely support renewable energy expansion.
In critical installations, the same technology can add continuity and quality, provided that...
Strategy: Reserve energy for contingencies. The energy benefit does not eliminate safety risks.
degradation or supply chain, which need to be incorporated into the specification and operation.
(IEA, 2024).

The graph presented summarizes only two observed points from the international series and does not constitute...
Projection. Its purpose is to highlight the change in scale of solar power generation over four years. Comparisons.
Temporary projects require consistent unity and scope, which is why global installed capacity is used.
expressed in gigawatts. The proper interpretation is not that all capacity can operate in a way
isolated, but network and asset planning must accommodate a growing participation of
Inverter-based resources.

The local use of solar generation for resilience depends on islanding requirements. Many systems
Connected devices disconnect during a network outage to protect workers and equipment.
Continuity requires an architecture capable of electrically isolating the installation, establishing voltage, and...
Frequency response, coordinate protections, and manage power balance. Without these functions, panels...
Installed systems may remain unavailable precisely during the outage. This distinction between
Distributed generation and microgrids are essential to avoid simplistic interpretations.

The combination of solar growth and storage creates opportunities, but does not eliminate the role of solar energy.
from dispatchable sources at long events or in locations with low renewable availability. A
A hybrid solution allows for the distribution of functions among resources and reduces dependence on a single mode of...
failure. Its performance must be demonstrated through simulation, testing, and monitoring. The transition
From this perspective, energy efficiency doesn't just mean replacing equipment, but reorganizing the...
Reliability architecture and asset management.

3. The term microgrid implies the ability to control resources and loads within defined electrical limits, with the possibility of connected or isolated operation as planned.

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google
NOMOS - Multidisciplinary Scientific Journal
Knowledge. ISSN: 2675-9128. São Paulo-SP.

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025




Figure 1. Global photovoltaic solar capacity in 2020 and 2024. Source: author's elaboration with data IRENA (2025).

5. Protection, safety and power quality

Microgrids and hybrid systems modify current levels and directions. Protections designed for Unidirectional flow can lose sensitivity or selectivity during islanding. Inverters They typically limit fault current, while synchronous generators contribute differently. Short-circuit studies should consider possible operating states and adjust devices accordingly. compromising the protection of people or equipment. Coordination needs to cover overcurrent, ground fault, voltage, frequency, reverse power, and synchronization conditions.4 The grounding scheme can change between connected and isolated operation. The conductor position Neutrality, the existence of a separately derived source, and pole switching influence detection. due to fouls and touch tensions. A technically functional transfer can remain insecure. If the reference to land has not been analyzed, the project must represent each mode and document it. Current paths and verify compliance with applicable standards. Electrical safety is an attribute. of architecture, not a documentary supplement.

Power quality includes variations in voltage, frequency, harmonics, imbalance, flicker, and... Transients. Sensitive electronic loads and converters can interact, especially in networks of Low short-circuit power. The modeling should evaluate stability and distortion, while the

4. Interconnection standards and requirements must be verified in the current edition and jurisdiction of the project.

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

Commissioning confirms actual parameters. The presence of batteries does not guarantee quality.
Automatically. Inadequate control, poorly sized filters, or resonances can introduce...
new problems. Continuous measurement allows you to identify trends before they become problems.
unavailability.
Storage safety requires assessment of chemistry, thermal propagation, detection,
Ventilation, suppression, clearances, access, and emergency response. The probability of an incident.
It may be low, but the consequences justify independent barriers. The project should consider
Manufacturer information, technical standards and environmental conditions. Inspection and training plans.
They need to monitor the asset throughout its useful life. Engineering should not transfer all of that responsibility.
Risk management for the electronic battery system.
Integrated commissioning tests functions that individual verification cannot achieve. They must be
simulated network loss, startup failure, battery unavailability, power supply return, rejection of
Charge and communication are interrupted. Tests need to be planned so as not to expose people or
Processes that pose undue risk. Results, adjustments, and limitations should be documented. Repetition
Periodic critical testing is necessary because software, load, fuel, and condition of
Components change over time.

6. Operation, maintenance and performance governance

The designed resilience only remains valid when the operation preserves essential assumptions.
Changes in load, expansions, new equipment, and changes in usage can erode profit margins.
without formal review. A change management process should assess the impact on power,
Autonomy, protection, and restoration sequence. Diagrams, load lists, and logic are needed.
reflect the actual configuration. Discrepancies between documentation and field performance reduce reliability.
It makes maneuvering difficult and hinders incident response.
Calendar-based maintenance can be supplemented by condition and criticality considerations.
Module temperature, internal resistance, number of cycles, fuel quality, vibration,
Pressure, alarms, and match history help anticipate failures. Indicators should be few.
Reliable and decision-making-related data. Collecting data without interpretation criteria increases complexity.
without improving performance. Governance defines responsibilities, alarm thresholds, and deadlines.
Intervention and evidence of closure.
Autonomy tests need to take into account that completely discharging a battery or operating a
Generator operation over a long period can impose costs and risks. Partial testing methods, trend analysis
Simulations can reduce exposure, but they do not replace all physical verification. The frequency should

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

Reflect criticality and historical context. When a test finds a flaw, the correction should include cause and effect.
Regarding other functions and the need to review design assumptions. Operational learning concludes.
the engineering cycle.
Fuel logistics remain crucial at regional events. Blocked roads, high
Demand and storage restrictions may limit replenishment. The nominal autonomy should be
interpreted in light of usable quantity, variable load consumption, and product quality.
Hybrid strategies can reduce consumption and extend inventory, while contracts and plans of
Emergency measures improve replenishment. No single measure guarantees continuity; robustness results from...
technical diversity and organizational preparedness.
Governance should also include cybersecurity, as controllers, inverters, and systems...
Supervisory systems and remote platforms expand the digital surface. Access privileges, updates,
Event logging, segmentation, and configuration recovery are required. An incident
Cybersecurity can prevent commands or change parameters without initial physical damage. Integrate security.
Digitalization of electrical maintenance prevents automation, created to increase resilience, from becoming...
at a new single point of failure.

7. Economic evaluation and life cycle decision-making

The economic evaluation of resilient systems needs to combine monetary flows and consequences.
Operational costs. Initial investment, battery replacement, fuel consumption, maintenance,
Tariffs, losses, and residual value make up the life cycle cost. Savings on the energy bill
This alone does not represent the value of continuity. For critical loads, costs must be examined.
avoided interruptions, loss of production, data recovery, product deterioration and
emergency mobilization. Since these values have uncertainty, it is advisable to work with intervals and
scenarios, avoiding turning an estimate into apparent precision.
The analysis horizon should reflect different lifespans. Photovoltaic modules, inverters, batteries,
Generators and control systems don't age at the same rate. Replacements need to be...
positioned in the cash flow, with consistent depreciation and inflation assumptions. The discount rate
It influences the comparison between a high initial investment and future expenses. A decision
Transparent, it presents the values used and shows how the result changes in response to variations.
Sensitivity analysis is especially important in technologies where price and performance are crucial.
They evolve rapidly.
Tariffs based on demand, schedules, and penalties can make storage economically viable.
Attractive even without interruption. However, the dispatch for cost reduction may compete with

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

the resilience reserve. Optimization should explicitly prioritize continuity or calculate the
The value of maintaining a given state of load. Adaptive rules can consider forecasting.
Storm or risk of network failure, but they require data and monitoring. The operational economics are not
It should quietly consume the margin allocated for critical events.
Environmental externalities are also part of the decision. Reducing generator operating hours decreases
Local consumption, noise, and emissions are factors to consider, while batteries and panels have manufacturing impacts.
transport and end-of-life. A responsible comparison uses consistent boundaries and recognizes that
Emissions vary depending on fuel type, efficiency, electricity mix, and recycling. The goal is not...
to declare a technology universally clean, but to choose a combination that reduces impacts.
maintaining function and safety.
Multi-criteria criteria can organize reliability, cost, emissions, space, noise, maintenance and
Supplier availability. Weights should be defined by those responsible and the affected parties, because
These are not natural properties of the equipment. The result serves to document preferences and
Conflicts, not to produce an automatic truth. Robust decisions tend to remain.
acceptable in different scenarios, even when they are not optimal in a single forecast.

8. Critical discussion and development agenda

The literature converges in recognizing that resource diversity can increase resilience, but diverges.
Regarding how to measure benefit, studies use failure durations, load profiles, climate, and costs.
distinct. Comparing results without these conditions can lead to misleading conclusions. One
A useful research agenda should publish sufficient sets of assumptions, models, and data to...
reproduction, in addition to including component failures and operational behavior.
Another gap lies in long-term validation. Many studies simulate performance, while
Few people monitor systems for years to correlate degradation, maintenance, and real-world events.
Anonymized operational data could improve reliability parameters. However,
Critical facilities have security and confidentiality restrictions. Protocols of
Sharing should balance knowledge and protection.
The increasing use of inverters demands improved methods for stability and protection.
Aggregated models may not represent proprietary controls, and firmware updates
They alter behavior. Compliance tests, validated models, and parameter documentation.
Cooperation between manufacturers, designers, operators, and researchers becomes important.
Reduce uncertainty without exposing sensitive information.

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

In countries and regions with unequal infrastructure, solutions need to consider local capacity to...
maintenance. A sophisticated system may exhibit less practical resilience if parts, support, and
Training is not available. Modular projects, clear documentation, and strategies for
Degraded operation can increase robustness. Engineering must adapt technology to the context in
Instead of assuming uniform institutional conditions.
The main implication is that resilience should be treated as verifiable performance. Requirements
These requirements need to be defined before selection, demonstrated during commissioning, and monitored throughout.
the useful life. Future research should bring together modeling, field data, human factors and
economy. This integration will allow for a more rigorous comparison of solutions and prevent resilience from being...
used only as a generic expression of value.

Conclusion

The energy resilience of critical facilities is a property of the entire system. Power
installed battery capacity and fuel volume are insufficient when controls,
Protection, transfer, and operation were not coordinated. The project should begin with the functions.
priorities, acceptable timeframes, and consequences of failure.
The complementarity between photovoltaic generation, storage, and generating units expands
Alternatives. The battery offers quick response and flexibility, the solar source contributes energy.
The renewable energy source and the generator sustain prolonged events. The combination reduces dependence on a single source.
It's a great feature, but it creates interfaces that require detailed engineering.
The sizing should account for time series, seasonality, degradation, and failures. Averages
Annual deadlines do not determine autonomy during contingencies. Sensitivity analysis and scenarios
They allow us to understand which assumptions dominate the outcome and where reservations are needed.
The global expansion of solar power confirms the relevance of integrating inverter-based resources.
However, connected generation does not equate to islanding capability. Continuity requires
Separation, electrical reference, control and protection are compatible.
Safety and power quality cannot be addressed after equipment selection.
Grounding, fault currents, harmonics, storage hazards, and operational transitions.
They determine whether the system can function without creating new exposures.
Integrated commissioning constitutes essential evidence. Testing for network loss and return, failure of
Load rejection and resource analysis reveal interactions that isolated tests do not show. The documentation
The results preserve knowledge for maintenance.

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.

Machine Translated by Google

Year VI, v.2 2025 | Submission: 12/22/2025 | Accepted: 12/25/2025 | Publication: 12/28/2025

Throughout the product lifecycle, change management, condition data, fuel logistics and...

Cybersecurity underpins performance. The installation evolves, and its assumptions must be reviewed.

Resilience is an ongoing practice, not a permanent trait gained upon delivery.

It can be concluded that hybrid systems can increase continuity and efficiency when subjected to

Measurable criteria, coherent architecture, and governance. Responsible decision-making combines...

Modeling, standards, testing, and professional judgment, while keeping the limitations of each explicit.

source and each piece of evidence.

References

ANDERSON, K. et al. Microgrids for energy resilience: a guide to conceptual design and lessons from defense projects. Golden: National Renewable Energy Laboratory, 2019.
HIRSCH, A.; PARAG, Y.; GUERRERO, J. Microgrids: a review of technologies, key drivers, and outstanding issues. Renewable and Sustainable Energy Reviews, vol. 90, p. 402 to 411, 2018. DOI: 10.1016/j.rser.2018.03.040.

HERVÁS ZARAGOZA, J. et al. Microgrids as a mechanism for improving energy resilience during grid outages: a post COVID 19 case study for hospitals. Renewable Energy, vol. 199, p. 308 to 319, 2022. DOI: 10.1016/j.renene.2022.08.132.
HWANG, S.; TONGSOPIT, S.; KITTNER, N. Transitioning from diesel backup generators to photovoltaic plus storage microgrids in California public buildings. Sustainable Production and Consumption, v. 38, p. 252 to 265, 2023. DOI: 10.1016/j.spc.2023.04.001.
IEA. Power systems in transition: challenges and opportunities ahead for electricity security. Paris: International Energy Agency, 2020.
IEA. Secure energy transitions in the power sector. Paris: International Energy Agency, 2021.
IEA. Batteries and secure energy transitions. Paris: International Energy Agency, 2024.
IEA. World energy investment 2025. Paris: International Energy Agency, 2025.
IRENA. Renewable capacity statistics 2025. Abu Dhabi: International Renewable Energy Agency, 2025.

MARQUSEE, J.; BECKER, W.; ERICSON, S. Resilience and economics of microgrids with photovoltaic generation, battery storage, and networked diesel generators. Advances in Applied
Energy, vol. 3, 100049, 2021. DOI: 10.1016/j.adapen.2021.100049.
NELSON, JR; JOHNSON, NG Statistical development of microgrid resilience during islanding operations. Applied Energy, vol. 279, 2020. DOI: 10.1016/j.apenergy.2020.115724.
SEPÚLVEDA MORA, SB; Hegedus, S. Resilience analysis of renewable microgrids for commercial buildings with different usage patterns and weather conditions. Renewable Energy, vol. 192, p. 731 to 744, 2022. DOI: 10.1016/j.renene.2022.04.090.
TON, DT; SMITH, MA The United States experience with the development and deployment of microgrids. The Electricity Journal, vol. 25, no. 8, p. 84 to 94, 2012. DOI: 10.1016/j.tej.2012.09.013.

This is an open access article published under the Creative Commons Attribution license, which allows its use.
Distribution and reproduction in any medium, without restrictions, provided the original work is properly cited.